



City of Johannesburg
Johannesburg Water (SOC) Ltd

17 Harrison Street
Johannesburg

Johannesburg Water
PO Box 61542
Marshalltown

Tel +27(0) 11 483-9600
Fax +27(0) 11483-9564

www.johannesburgwater.co.za

QUALITY OF WATER SUPPLIED IN JOHANNESBURG

March-19

Microbiological safety requirements

		Limit	Compliance Target %	Compliance Achieved %	Number of tests	Number of non-compliances
E.coli	count/100ml	0	99.0	99.7	700	2

Physical, organoleptic and chemical requirements

		Limit	Compliance Target %	Compliance Achieved %	Number of tests	Number of non-compliances
Chemical & Physical properties						
Colour	mg/L as Pt	20	95	100	693	0
Conductivity	mS/m	150	95	100	694	0
Odour	TON	5	95	100	59	0
pH	pH units	5.0 - 9.5	95	100	700	0
Taste	TTN	5	95	100	59	0
Turbidity	NTU	1	95	99	694	6
Chemical requirements - macro-determinand						
Ammonia	mg/L as N	1	95	100	57	0
Calcium	mg/L as Ca	150	95	100	59	0
Chloride	mg/L as Cl	200	95	100	57	0
Fluoride	mg/L as F	1	95	100	57	0
Magnesium	mg/L as Mg	70	95	100	59	0
Nitrate and nitrite	mg/L as N	10	95	100	57	0
Potassium	mg/L as K	50	95	100	59	0
Sodium	mg/L as Na	200	95	100	59	0
Sulphate	mg/L as SO ₄	400	95	100	57	0
Zinc	mg/L as Zn	5	95	100	59	0
Chemical requirements - micro-determinand						
Aluminium	mg/L as Al	0.3	95	100	59	0
Antimony	µg/L as Sb	10	95	100	59	0
Arsenic	µg/L as As	10	95	100	59	0
Cadmium	µg/L as Cd	5	95	100	59	0
Chromium	µg/L as Cr	100	95	100	59	0
Cobalt	µg/L as Co	500	95	100	59	0
Copper	mg/L as Cu	1	95	100	59	0
Cyanide (Free)	µg/L as CN	50	95	100	59	0
Iron	mg/L as Fe	0.2	95	100	59	0
Lead	µg/L as Pb	20	95	100	59	0
Manganese	mg/L as Mn	0.1	95	100	59	0
Mercury	µg/L as Hg	2	95	100	59	0
Nickel	µg/L as Ni	150	95	100	59	0
Selenium	µg/L as Se	20	95	100	59	0
Vanadium	µg/L as V	200	95	100	59	0
Chemical requirements - organic determinands						
Dissolved Organic Carbon	mg/L as C	10	95	100	59	0
Total Trihalomethanes	µg/L	200	95	100	10	0
Phenols as C ₆ H ₅ OH	µg/L	10	95	100	59	0
Free chlorine	mg/L				700	0
Monochloramine	mg/L				700	0

Johannesburg Water supplies water to the Johannesburg Metropolitan area.

This water is tested regularly and is compared to the SABS National Standard SANS 241-1 : 2015

Further information on the quality of water in Johannesburg is also available at the following web sites:

www.johannesburgwater.co.za

www.dwa.gov.za/dir_ws/dwqr

<https://www.johannesburgwater.co.za/about/resource-centre/>