



City of Johannesburg  
Johannesburg Water (SOC) Ltd

17 Harrison Street  
Johannesburg

Johannesburg Water  
PO Box 61542  
Marshalltown  
2107

Tel +27(0) 11 688 1400  
Fax +27(0) 11 688 1528

a world class African city

www.johannesburgwater.co.za

**QUALITY OF WATER SUPPLIED IN JOHANNESBURG**  
September-14

**Microbiological safety requirements**

		Limit	Compliance Target %	Compliance Achieved %	Number of tests	Number of non-compliances
E.coli	count/100ml	0	99.8	100	575	0

**Physical, organoleptic and chemical requirements**

		Class 1 Limit	Compliance Target %	Compliance Achieved %	Number of tests	Number of non-compliances
<b>Chemical &amp; Physical properties</b>						
Colour	mg/L as Pt	20	95	100	560	0
Conductivity	mS/m	150	95	100	560	0
Odour	TON	5	95	100	44	0
pH	pH units	5.0 - 9.5	95	100	575	0
Taste	TTN	5	95	100	44	0
Turbidity	NTU	1	95	100	560	2
<b>Chemical requirements - macro-determinand</b>						
Ammonia	mg/L as N	1	95	100		0
Calcium	mg/L as Ca	150	95	100	44	0
Chloride	mg/L as Cl	200	95	100		0
Fluoride	mg/L as F	1	95	100		0
Magnesium	mg/L as Mg	70	95	100	44	0
Nitrate and nitrite	mg/L as N	10	95	100		0
Potassium	mg/L as K	50	95	100	44	0
Sodium	mg/L as Na	200	95	100	44	0
Sulphate	mg/L as SO <sub>4</sub>	400	95	100		0
Zinc	mg/L as Zn	5	95	100	44	0
<b>Chemical requirements - micro-determinand</b>						
Aluminium	mg/L as Al	0.3	95	100	44	0
Antimony	µg/L as Sb	10	95	100	44	0
Arsenic	µg/L as As	10	95	100	44	0
Cadmium	µg/L as Cd	5	95	100	44	0
Chromium	µg/L as Cr	100	95	100	44	0
Cobalt	µg/L as Co	500	95	100	44	0
Copper	mg/L as Cu	1	95	100	44	0
Cyanide (Free)	µg/L as CN	50	95	100	43	0
Iron	mg/L as Fe	0.2	95	100	44	0
Lead	µg/L as Pb	20	95	100	44	0
Manganese	mg/L as Mn	0.1	95	100	44	0
Mercury	µg/L as Hg	2	95	100	44	0
Nickel	µg/L as Ni	150	95	100	44	0
Selenium	µg/L as Se	20	95	100	44	0
Vanadium	µg/L as V	200	95	100	44	0
<b>Chemical requirements - organic determinands</b>						
Dissolved Organic Carbon	mg/L as C	10	95	100	44	0
Total Trihalomethanes	µg/L	200	95	100	10	0
Phenols as C <sub>6</sub> H <sub>5</sub> OH	µg/L	10	95	100	43	0
Free chlorine	mg/L				575	0
Monochlorine					575	0

Johannesburg Water supplies water to the Johannesburg Metropolitan area.

This water is tested regularly and is compared to the SABS National Standard SANS 241 Edition 6.1

Further information on the quality of water in Johannesburg is also available at the following web sites:

[www.johannesburgwater.co.za](http://www.johannesburgwater.co.za)  
[www.dwa.gov.za/dir\\_ws/dwqr](http://www.dwa.gov.za/dir_ws/dwqr)