

17 Harrison Street  
 Marshalltown  
 P O Box 61542  
 Marshalltown 2107  
 Tel : (011) 688-1400 Fax : (011) 688-1556



PAGE NO.	
CLOSING DATE AND TIME	
14-Dec-21	16:00
Date of Issue	
07 December 2021	
VALIDITY	
60 DAYS	

INITIATING DEPARTMENT	INITIATOR
METERING - FFENNEL ROAD	VASUTHAVEN MOODLEY

JWRFP483 - SUPPLY AND DELIVERY OF CONCRETE BUNKERS

QUOTATION REFERENCE	COLLECTIVE NO.

**REQUEST FOR QUOTATION**

QUOTATION DATE
60 Days

QUOTATION REQUESTED FROM

QUOTATIONS WILL BE EVALUATED ON THE 80/20 POINT SCORING SYSTEM.80 POINTS WILL BE ALLOCATED TO PRICE AND THE REMAINING 20 POINTS WILL BE ALLOCATED FOR BBBEE AND PREFERENTIAL PROCUREMENT  
 ALL SUPPLIERS RESPONDING TO QUOTATIONS SHOULD BE REGISTERED ON CENTRAL SUPPLIER DATABASE(CSD)  
 JW CONTACT PERSON: Paul Mabatane Mangoale  
 Tel: (011) 688 1408 Fax (011) 688 1556 Email: paul.mangoale@jwater.co.za

ITEM NO.	DESCRIPTION	BRAND NAME OFFERED	UOM	QTY REQUIRED	PRICE QUOTED EXCL. OF V.A.T.	DIS
	SUPPLY AND DELIVERY OF CONCRETE BUNKERS AS PER SPECIFICATION BELOW					
	DELIVERY MUST BE @ JOHANNESBURG WATER (SOC) LTD NO.1 FENNEL ROAD VILLAGE MAIN JOHANNESBURG					
1	<b>CONCRETE BUNKER SPECIFICATION</b>					
	THE DIMENSIONS OF THE BUNKERS MUST BE OF LENGTH 1442 x DEPTH 502 TOP AND BOTTOM 695 X WIDTH 796			8		
	THE DOOR MUST BE 5MM THICK GRADE S355 NITRIDED TO ROCKWELL					
	THE LIFTING EYE BOLT ON THE TOP OF THE BUNKER MUST BE M24					
	A STAINLESS STEEL GLAND PLATE MUST BE PROVIDED WITH 6 HOLES PUNCHED OF DIAMETER 20MM.					
	THE CONCRETE STRENGTH MUST BE > 55MPA AND COLORED WITH A HIGH QUALITY PVA LIGHT GREY GREEN					
	THE BUNKER MUST BE COATED WITH A BONDING LIQUID					
	THE CONCRETE BUNKER MUST BE FITTED WITH A 6M THICK INSULATED CHASSIS PLATE FOR THE MOUNTING OF EQUIPMENT					
	THE CHASSIS PLATE MUST BE BOLTED INTO THE BUNKER WITH A PROVIDED M10 SS THREADED ROD AND DOME NUTS					
	ATTACHED, PLEASE FIND A SKETCH OF THE BUNKER					
2	DELIVERY OF CONCRETE BUNKERS WITH CRANE TRUCK TO JOHANNESBURG WATER (SOC) LTD 1 FENNEL ROAD			1		
	VILLAGE MAIN JOHANNESBURG					
	<b>NB:</b>					
	SUPPLIERS MUST SUPPLY A DETAILED DRAWING OF THE BUNKER QUOTED ON (DO NOT USE THE JW ONE SUPPLIED)					
	THE DRAWING MUST CLEARLY DEFINE ALL THE DIMENSIONS					
	QUOTES WILL NOT BE CONSIDERED FOR TECHNICAL EVALUATION IF NO DETAILED DRAWING IS SENT WITH QUOTE					

<b>SUPPLIER DETAILS</b>		<b>CONDITIONS</b>
OFFICIAL STAMP	AUTHORISED BY: ..... SIGNATURE:..... DATE:.....	1. QUOTATIONS RECEIVED AFTER CLOSE OF BUSINESS ON THE CLOSING DATE WILL NOT BE ACCEPTED. 2. QUOTATIONS WITHOUT BRAND NAMES WHERE REQUIRED WILL NOT BE ACCEPTED 3. PRICES QUOTED MUST BE AS PER THE UNIT INDICATED AND BE EXCLUDED OF VAT 4 QUOTATIONS WITHOUT THE SUPPLIER'S AUTHORISED SIGNATURE WILL NOT BE ACCEPTED. 5 ACCEPTANCE OF A QUOTATION WILL BE SUBJECT TO JOHANNESBURG WATER'S SUPPLY CHAIN POLICY